### **Ministry Inspections**

An onsite MECP inspection of the Armow Drinking Water system took place on June 14. No issues noted on site. Requested documents were sent for review. MECP report is not yet completed.

The MECP inspection report for the Tiverton Drinking Water System conducted on April 20, 2022 was received. No issues of non-compliance were noted. MECP inspection report placed on Consent Agenda.

### **Drinking Water Quality Management System**

The QMS Operational Plan Revision 8 and QMS Policy Revision 3 were endorsed by Kincardine Council on June 6.

The Huronville QMS Operational Plan Revision 8 and QMS Policy Revision 3 were endorsed by Huron Kinloss Council on June 6.

All documents were put into circulation for staff use and placed on the website for public viewing. An internal audit of QMS documentation was completed by staff June 15 and 16. No corrective actions were identified.

#### **Annual Calibrations**

Annual Calibrations of all water and wastewater flowmeters and regulatory monitoring equipment were completed by outside contractors. All units passed calibrations but 2 were identified that should be replaced. Staff will budget for new equipment.

# **Tiverton Water System**

The Briar Hill Well #2 video inspection and report was received back from W.D. Hopper and Sons Ltd. A well cleaning was performed with air lifting and brushing. The report notes some corrosion points still visible which are moderate to medium in nature with the most significant corrosion points around 83-92 ft.

# **Kincardine Wastewater System**

A planned bypass of the aeration cell at the Kincardine Wastewater Treatment Plant took place from June 14 to 17 for the new Huron Terrace Forcemain to be tied into the treatment system. Finnbilt Contracting completed the work. Sampling was completed during the bypass as per the MECP requirements in the Planned Bypass Letter of Consent and the ECA.

Lisa Crimmings
Environmental Compliance Officer