

Ministry of the Environment, Conservation and Parks - Inspection Summary Rating Record (Reporting Year - 2023-24)

DWS Name: KINCARDINE DRINKING WATER SYSTEM
DWS Number: 220002716
DWS Owner: CORPORATION OF THE MUNICIPALITY OF KINCARDINE
Municipal Location: KINCARDINE

Regulation: O.REG. 170/03
DWS Category: DW Municipal Residential
Type of Inspection: Focused
Inspection Date: Sep-20-2023
Ministry Office: Owen Sound District Office

Maximum Risk Rating: 564

Inspection Module	Non Compliance Risk (X out of Y)
Capacity Assessment	0/30
Certification and Training	0/42
Logbooks	0/18
Operations Manuals	0/28
Reporting & Corrective Actions	0/91
Source	0/0
Treatment Processes	21/243
Water Quality Monitoring	0/112
Overall - Calculated	21/564

Inspection Risk Rating: 3.72%

Final Inspection Rating: 96.28%

Ministry of the Environment, Conservation and Parks - Detailed Inspection Rating Record (Reporting Year - 2023-24)

DWS Name: KINCARDINE DRINKING WATER SYSTEM
DWS Number: 220002716
DWS Owner Name: CORPORATION OF THE MUNICIPALITY OF KINCARDINE
Municipal Location: KINCARDINE

Regulation: O.REG. 170/03
DWS Category: DW Municipal Residential
Type of Inspection: Focused
Inspection Date: Sep-20-2023
Ministry Office: Owen Sound District Office

Non-Compliance Question(s)	Non Compliance Risk
Treatment Processes	
Do records indicate that the treatment equipment was operated in a manner that achieved the design capabilities required under Ontario Regulation 170/03 or a DWWP and/or MDWL issued under Part V of the SDWA at all times that water was being supplied to consumers?	21
Overall - Total	21

Maximum Question Rating: 564

Inspection Risk Rating: 3.72%

FINAL INSPECTION RATING: 96.28%